


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 103.71 lm/W			
MODEL:UP-DL222-8-10W-C3-3000K		I _{max} (cd)	362.2	S/MH(C0/180)	1.25
NOMINAL POWER(W)	10	LOR(%)	100.0	S/MH(C90/270)	1.26
RATED VOLTAGE(V)	230	TOTAL FLUX(lm)	1030.9	η UP,DN(C0-180)	0.0,49.6
NOMINAL FLUX(lm)	1030.92	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,50.4
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	230.1	η down(%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	354.8	354.4	354.3	355.6	355.6	355.8	356.3	354.9	0- 10	34.24	34.24	3.32,3.32
20	335.4	335.6	335.9	337.6	338.4	338.4	338.2	336.3	10- 20	98.11	132.3	12.8,12.8
30	304.5	304.6	305.5	307.7	309.2	308.8	308.0	305.9	20- 30	149.0	281.4	27.3,27.3
40	262.6	263.0	264.4	266.8	268.8	268.1	267.0	264.5	30- 40	179.8	461.1	44.7,44.7
50	211.7	212.1	213.9	216.5	219.1	218.0	216.4	214.1	40- 50	186.2	647.3	62.8,62.8
60	153.7	154.6	156.7	159.2	162.4	160.6	158.5	156.5	50- 60	167.1	814.4	79.7,79
70	93.54	94.28	96.12	98.80	102.0	100.0	97.78	96.19	60- 70	126.3	940.7	91.2,91.2
80	37.11	37.20	38.85	41.00	44.33	42.31	40.35	39.00	70- 80	71.76	1012	98.2,98.2
90	0.2154	0.1914	0.1855	0.1975	0.6463	0.3709	0.2873	0.3022	80- 90	18.47	1031	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		


C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.04	.00	.96	1.02	.98	.94	.97	.94	.91	.93	.91	.88	.90	.88	.86	.84
2.0	.91	.84	.78	.89	.82	.77	.85	.80	.75	.82	.77	.73	.79	.75	.72	.70
3.0	.79	.71	.65	.78	.70	.64	.75	.68	.63	.72	.67	.62	.70	.65	.61	.59
4.0	.70	.62	.55	.69	.61	.54	.66	.59	.54	.64	.58	.53	.62	.57	.52	.50
5.0	.63	.54	.47	.62	.53	.47	.60	.52	.46	.58	.51	.46	.56	.50	.45	.43
6.0	.57	.48	.41	.56	.47	.41	.54	.46	.41	.52	.45	.40	.50	.44	.40	.38
7.0	.51	.42	.36	.50	.42	.36	.49	.41	.36	.47	.41	.36	.46	.40	.35	.33
8.0	.47	.38	.32	.46	.38	.32	.45	.37	.32	.43	.37	.32	.42	.36	.32	.30
9.0	.43	.35	.29	.42	.34	.29	.41	.34	.29	.40	.33	.29	.39	.33	.29	.27
10.0	.40	.32	.26	.39	.31	.26	.38	.31	.26	.37	.31	.26	.36	.30	.26	.24



C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:DAMIN
 Test Date:2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
 Humidity:65.0%
 Test Distance:9.443m [K=1.0000]
 Remarks:

WEC AND CCEC

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm								
NAME: UP-DL222-8-10W-C3-3000K				TYPE:10W			WEIGHT:	
DIM.:				SPEC.:3000K			SERIAL No.:1	
MFR.:				SUR.:0.0232			PROTECTION ANGLE:	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.308	.175	.056	.301	.172	.055	.288	.165	.053	.276	.159	.051	.265	.153	.049	
2.0	.291	.159	.049	.285	.157	.048	.273	.152	.047	.262	.147	.046	.252	.143	.045	
3.0	.269	.143	.043	.264	.141	.043	.254	.137	.042	.244	.134	.041	.235	.130	.040	
4.0	.249	.129	.038	.244	.128	.038	.235	.125	.037	.226	.122	.037	.218	.119	.036	
5.0	.230	.117	.034	.226	.116	.034	.218	.113	.033	.210	.111	.033	.203	.108	.033	
6.0	.213	.107	.031	.210	.106	.030	.202	.104	.030	.196	.102	.030	.189	.100	.030	
7.0	.199	.098	.028	.195	.097	.028	.189	.095	.027	.183	.094	.027	.177	.092	.027	
8.0	.186	.091	.025	.183	.090	.025	.177	.088	.025	.171	.087	.025	.166	.085	.025	
9.0	.174	.084	.023	.171	.083	.023	.166	.082	.023	.161	.081	.023	.156	.079	.023	
10.0	.164	.078	.022	.161	.078	.022	.156	.077	.022	.152	.075	.021	.148	.074	.021	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.180	.156	.134	.154	.134	.116	.105	.092	.080	.061	.053	.047	.019	.017	.015	
2.0	.172	.132	.098	.147	.114	.085	.101	.079	.059	.058	.046	.035	.019	.015	.011	
3.0	.164	.114	.074	.141	.099	.064	.097	.068	.045	.056	.040	.027	.018	.013	.009	
4.0	.157	.101	.058	.135	.087	.051	.093	.061	.036	.054	.036	.021	.017	.012	.007	
5.0	.149	.091	.047	.128	.078	.041	.088	.055	.029	.051	.032	.017	.016	.010	.006	
6.0	.142	.082	.039	.122	.071	.034	.084	.050	.024	.049	.029	.014	.016	.010	.005	
7.0	.135	.075	.033	.116	.065	.029	.080	.046	.021	.047	.027	.012	.015	.009	.004	
8.0	.129	.070	.029	.111	.060	.025	.077	.042	.018	.045	.025	.011	.014	.008	.004	
9.0	.123	.065	.025	.106	.056	.022	.073	.039	.016	.043	.023	.009	.014	.008	.003	
10.0	.117	.060	.022	.101	.052	.020	.070	.037	.014	.041	.022	.008	.013	.007	.003	

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

Uncorrected UGR Table

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm										
NAME: UP-DL222-8-10W-C3-3000K					TYPE:10W			WEIGHT:		
DIM.:					SPEC.:3000K			SERIAL No.:1		
MFR.:					SUR.:0.0232			PROTECTION ANGLE:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	21.9	23.4	22.2	23.6	23.8	22.0	23.5	22.2	23.7	23.9
3H	23.4	24.8	23.7	25.0	25.2	23.4	24.9	23.7	25.1	25.3
4H	23.9	25.3	24.2	25.5	25.8	24.0	25.4	24.3	25.6	25.9
6H	24.3	25.6	24.6	25.8	26.1	24.4	25.7	24.7	25.9	26.2
8H	24.4	25.6	24.7	25.9	26.2	24.5	25.7	24.9	26.0	26.3
12H	24.4	25.6	24.8	25.9	26.2	24.6	25.7	24.9	26.0	26.3
4H 2H	22.5	23.9	22.8	24.1	24.4	22.6	23.9	22.9	24.1	24.4
3H	24.1	25.3	24.5	25.6	25.9	24.2	25.4	24.6	25.7	26.0
4H	24.8	25.9	25.2	26.2	26.5	24.9	26.0	25.3	26.3	26.6
6H	25.3	26.3	25.7	26.6	27.0	25.4	26.4	25.8	26.7	27.1
8H	25.5	26.3	25.9	26.7	27.1	25.6	26.4	26.0	26.8	27.2
12H	25.5	26.4	26.0	26.7	27.1	25.6	26.5	26.1	26.8	27.2
8H 4H	25.1	26.0	25.5	26.3	26.7	25.1	26.0	25.5	26.4	26.8
6H	25.7	26.4	26.1	26.8	27.3	25.8	26.5	26.2	26.9	27.3
8H	25.9	26.6	26.4	27.0	27.4	26.0	26.6	26.5	27.1	27.5
12H	26.1	26.6	26.5	27.1	27.5	26.1	26.7	26.6	27.1	27.6
12H 4H	25.1	25.9	25.5	26.3	26.7	25.1	26.0	25.6	26.3	26.7
6H	25.7	26.4	26.2	26.8	27.3	25.8	26.5	26.3	26.9	27.3
8H	26.0	26.6	26.5	27.0	27.5	26.1	26.6	26.5	27.1	27.6
Variations with the observer position at spacings:										
S = 1.0H	+ 0.2 / - 0.2					+ 0.2 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117 Corrected 1031 lm Total Lamp Luminous Flux.(8log(F/F0) = 0.1)

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) k(RI) x RCR = 5									
k = 0.60	58	46	39	57	46	39	56	45	39	32
0.80	68	56	49	67	56	48	65	55	48	41
1.00	76	65	58	75	64	57	73	66	57	50
1.25	83	73	66	82	72	65	79	71	64	57
1.50	88	78	71	86	77	71	83	76	70	62
2.00	95	87	80	93	85	79	90	83	78	70
2.50	99	91	85	97	90	84	93	87	82	74
3.00	102	95	90	100	94	89	96	91	87	78
4.00	106	101	96	104	99	95	100	95	92	83
5.00	109	104	100	106	102	98	102	98	95	86
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004										
Suspended										
SHRNM = 1.25										

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:




C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

AAI Figure

Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:

Flux out:751.4 lm




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:230.1V I:0.0460A P:9.940W PF:0.9280 Lamp Flux:1030.92x1 lm		
NAME: UP-DL222-8-10W-C3-3000K	TYPE:10W	WEIGHT:
DIM.:	SPEC.:3000K	SERIAL No.:1
MFR.:	SUR.:0.0232	PROTECTION ANGLE:



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:DAMIN
Test Date:2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2019-05-27

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity: 65.0%
Test Distance: 9.443m [K=1.0000]
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.276
Humidity:65.0%
Test Distance:9.443m [K=1.0000]
Remarks:

```